

# GARR HOME INSPECTIONS, LLC

7207 SHEFFORD LANE  
LOUISVILLE KY 40242  
502-468-6510  
mgarr60@bellsouth.net

## Radon Test Report

February 05, 2018  
Batch #: 020518-1

---

---

**Customer:**

MARK GARR

**Test Site:**

7207 SHEFFORD LANE  
LOUISVILLE KY 40242

---

---

E-PERM® Electret Ion Chambers were used for short-term radon screening measurements that were conducted at the above referenced test site by: GARR HOME INSPECTIONS, LLC

**The Results are as follows:**

Serial No.	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SME123	SST	Basement	31-Jan-2018	12:00 PM	05-Feb-2018	12:00 PM	9.5
SME345	SST	Basement	31-Jan-2018	12:00 PM	05-Feb-2018	12:00 PM	9.5

---

**Average Radon Concentration in:      Basement      9.5 pCi/L**

**Deployed By:** MARK GARR      NRSB327

**Retrieved By:** MARK GARR      NRSB327

**Analyzed By:** MARK GARR      NRSB327

**Reader S/N:** E0394

**Reader Calibration Due:** 02-Oct-2018

**Conditions:**

**Tampering:**

**Weather:**

**Active Mitigation:**

**Comment:**

---

---

### Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (USEPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the USEPA web site at [www.USEPA.gov/radon](http://www.USEPA.gov/radon) for further information to assist you in evaluating your test results or deciding if further action is needed.

RADON MITIGATION CONTRACTOR - AQUA-LOCK - JAY A. KRAFT - (502) 495-9450

**Signature:** \_\_\_\_\_

**Date:** 05-Feb-2018